



Title of Report:	PPC Permit
Committee Report Submitted To:	Environmental Services Committee
Date of Meeting:	10th August 2021
For Decision or For Information	For Information

Linkage to Council Strategy (2019-23)	
Strategic Theme	Prosperity
Outcome	Actively develop and promote the economic and social development of the area
Lead Officer	Head of Health and Built Environment

Budgetary Considerations	
Cost of Proposal	Licensing Fee Applies
Included in Current Year Estimates	NO
Capital/Revenue	N/A
Code	N/A
Staffing Costs	N/A

Screening Requirements	Required for new or revised Policies, Plans, Strategies or Service Delivery Proposals.		
Section 75 Screening	Screening Completed:	N/A	Date:
	EQIA Required and Completed:	N/A	Date:
Rural Needs Assessment (RNA)	Screening Completed	N/A	Date:
	RNA Required and Completed:	N/A	Date:
Data Protection Impact Assessment (DPIA)	Screening Completed:	N/A	Date:
	DPIA Required and Completed:	N/A	Date:

1.0 PPC Permit

GRANT OF PPC PERMIT

Premises: Spar Mountsandel, Sandel Local Centre, Knocklynn Road, Coleraine

Application: An application has been received for a vapour recovery permit to operate an installation unloading petrol into stationary storage tanks (Stage 1) and motor vehicle refuelling activities (Stage 2), at the above service station.

The above service station has provided evidence to Council, confirming that the total quantity of petrol unloaded into the storage tanks is greater than 500m³, in any 12 month period. In addition, the premises have recently undergone a major refurbishment. This means that a stage 1 & 2 PPC permit is required

An inspection has been carried out and the premises complies with the vapour recovery measures required for a PPC Permit.

The permit has been granted under delegated authority.